

	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT SHORT TERM WATER ABSORPTION BY PARTIAL IMMERSION	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	1080675	Request No:	EMTX-2026-0002245
Project No:	CF-594	Report Date:	16/01/2026 11:58AM
Project Name:	ALWAN AL MATAR TECHNICAL SERVICE		
Consultant:	DUBAI MUNICIPALITY		
Contractor:	ALWAN AL MATAR TECHNICAL SERVICE		
Location: *	spray applied on the floor of one of the Site villas		
Source: *	NOT GIVEN		
Sample Description: *	SPRAY APPLIED RIGID CELLULAR POLYURETHANE INSULATION		
Product Name: *	Spray Applied Rigid Cellular Polyurethane Insulation		
Sampling Date/Time: *	10/12/2025 11:00AM	Lot/Batch/Coil/Heat No.*	-
Receiving Date/Time:	09/01/2026 10:18AM	Lot Size: *	-
Sample Size /Quantity:	10 pieces	Sender No:	SMP-AAM-001
Material/Mix Type: *	NA	Laying Date/Production Date: *	NA
Nominal Size / Working Block Size (mm) : 1000x500x50			

TEST RESULTS

PARAMETER	RESULTS			
SUPPORT / FACING*	NIL			
NOM. THICKNESS (mm)*	50			
NOM. DENSITY (kg/m3)*	40			
SPECIMEN NOM. THICKNESS (mm)	50			
TEST DURATION (h)	24			
SPECIMEN NO.	1	2	3	4
WATER ABSORPTION (kg/Square m)	0.03	0.02	0.03	0.03
AVG. WATER ABSORPTION (kg/Square m)	0.03			
Sampled By:	Subair Mada Puram		Tested By:	NASARDAR
Sampled Brought By:	CLIENT REPRESENTATIVE		Testing Date:	09/01/2026 10:18AM
Sampling Method:	SAMPLING AS PER THE RELEVANT SPECIFIC RULES		Sampling Report No:	NA
Test Method:	BS EN ISO 29767 : 2019		Test Method Variation:	NIL
Remarks:	CUSTOMER PERFORMED SAMPLING AND PROVIDED THE SAMPLE; THE RESULTS APPLY ONLY TO THE SAMPLE AS RECEIVED AND TESTED.			

Disclaimer : * Information is supplied by the customer and Laboratory is not responsible for this data.

	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT SHORT TERM WATER ABSORPTION BY PARTIAL IMMERSION	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	1080675	Request No: EMTX-2026-0002245
------------	---------	-------------------------------

To verify this document please go to : <https://www.dm.gov.ae/#check-tab3>
Enter Document ID: **EMTX-2026-0002245** and Verification Code: **1912109**
or Scan the QR code below.



***** END OF REPORT *****

This report is computer approved and authorized by In Charge of Lab and does not require any signature.



LB-TEST-014

PO Box 67, Dubai, UAE - Tel: (+971 4) 3027216 - Email: labs@dm.gov.ae - Website: <http://www.dm.gov.ae>

This report shall not be reproduced except in full without approval of the laboratory.

Date of Issue :	26/04/2024	Rev No. : 5
Shared - Confidential / مشترك - خاص	Level of Confidentiality / درجة السرية	Page 2 of 2